



HCK4-4 Check Valve

Specifications, Applications, Service Instructions & Parts

**HCK4 IN-LINE CHECK VALVES
5/8" THRU 4" PORT
(16 mm THRU 100 mm)**

**Flanged
3/8" thru 4"
(10 mm thru 100 mm)
FPT, SW, WN, ODS
for refrigerants**



INTRODUCTION

The HCK4 series of dependable, compact, rugged in-line check valves (disc type non-return valves) is ideally suited for refrigerant flow control applications. Valves open wide for flow in the arrow direction on the valve body. Valves close quickly and reliably when flow reversals occur.

Plated bodies and stainless steel seat discs and springs enable them to withstand expected industrial refrigeration conditions. Furthermore, these check valves can be mounted in any position and close-coupled to other valves.

ADVANTAGES


These compact check valves offer reliable operation regardless of position. Corrosion resistant stainless steel seat disc. Metal-to-metal seats facilitate durable, tight closing of valves.

APPLICATIONS

These valves are not recommended for use with pulsating loads or partial loads such as compressor discharge and side port applications.

These valves are not recommended for use with pulsating loads or partial loads such as compressor discharge and side port applications. For applications such as these, use Hansen HCK1 piston type check valves.

KEY FEATURES



ADDITIONAL FEATURES

Mounts in any position

Less than 1 psid wide opening pressure

Can be close-coupled

Low bubble leakage tolerance

For Ammonia, R22, R134a, CO2 and other approved refrigerants

U.L. Listed

MATERIAL SPECIFICATIONS

Body:

5/8" thru 1¼": Steel, ASTM A108, zinc chromate plated

1½" thru 4": Ductile iron, ASTM A536, zinc chromate plated

Seat Disc: Stainless steel

Seat Cartridge:

5/8" thru 1¼": Stainless steel, ASTM A582

1½" thru 4": Steel, ASTM A108, zinc chromate plated

Spring: Stainless steel

Safe Working Pressure: 400 psig (27 bar), 600 psig (40 bar) for CO₂


Operating Temperature: -60°F to 240°F (-50°C to 115°C)

INSTALLATION

Valve may be located in any position. Arrow on valve body should match direction of flow. Secure valve with gaskets between flanges and tighten bolts evenly. Do not use this valve or any component to align pipes or tighten gap between flanges.

Do not install on inlet side of solenoid valves or control valves with electric shut-off or shut-off valves unless a relief valve is used from therein between piping. Do not install on inlet side of outlet pressure regulators where liquid may become trapped. Instead, check valves should be located on outlet side of these valves. Check valves can be close-coupled to other matching solenoid valves, pressure regulators, or strainers by using a Male Adapter Ring and longer bolts supplied when so specified on order. For proper flange gasket sealing, care must be taken when threading or welding to assure flanges are parallel to each other and perpendicular to pipe. Also, gaskets should be lightly oiled and all bolts must be tightened evenly.

INSTALLATION DIMENSIONS



DIMENSION LETTER	HCK4-2 5/8" PORT	HCK4-3 3/4" PORT	HCK4-4 1" PORT	HCK4-5 1-1/4" PORT	HCK4-7 1-1/2" PORT	HCK4-8 2" PORT	HCK4-9 2-1/2" PORT	HCK4-0 3" PORT	HCK4-1 4" PORT
A	2.50" (64mm)	3.25" (83mm)	3.25" (83mm)	3.25" (83mm)	5.06" (129mm)	6.06" (154mm)	6.06" (154mm)	6.06" (154mm)	6.39" (162mm)
B	3.19" (81mm)	4.50" (114mm)	4.50" (114mm)	4.50" (114mm)	4.56" (116mm)	4.56" (116mm)	6.00" (152mm)	6.00" (152mm)	7.13" (181mm)
C	3.50" (89mm)	4.50" (114mm)	4.50" (114mm)	4.50" (114mm)	6.38" (162mm)	6.38" (162mm)	7.50" (191mm)	7.50" (191mm)	8.00" (203mm)
D	0.38" (10mm)	0.50" (13mm)	0.50" (13mm)	0.50" (13mm)	0.75" (19mm)	0.75" (19mm)	1.00" (25mm)	1.00" (25mm)	1.00" (25mm)
E	1.03" (26mm)	1.22" (31mm)	1.22" (31mm)	1.22" (31mm)	2.56" (65mm)	2.56" (65mm)	2.92" (74mm)	2.92" (74mm)	3.50" (89mm)
F	1.50" (38mm)	2.37" (60mm)	2.37" (60mm)	2.37" (60mm)	3.62" (92mm)	3.62" (92mm)	4.84" (123mm)	4.84" (123mm)	6.06" (154mm)
G	1.56" (20mm)	2.50" (64mm)	2.50" (64mm)	2.50" (64mm)	4.56" (116mm)	4.56" (116mm)	6.00" (152mm)	6.00" (152mm)	7.13" (181mm)
H	2.19" (56mm)	3.12" (79mm)	3.12" (79mm)	3.12" (79mm)	3.06" (78mm)	3.06" (78mm)	4.00" (102mm)	4.12" (105mm)	5.00" (127mm)
J	3.26" (83mm)	4.00" (102mm)	4.00" (102mm)	4.00" (102mm)	6.06" (154mm)	6.06" (154mm)	7.06" (179mm)	7.06" (179mm)	9.89" (251mm)
K	0.33" (8mm)	0.49" (12mm)	0.59" (15mm)	0.62" (16mm)	0.71" (18mm)	0.87" (22mm)	0.96" (24mm)	1.08" (27mm)	1.40" (36mm)
Valve Cv (Kv)	5.8 (5)	8.2 (7)	11.7 (10)	14.0 (12)	39 (33)	50 (43)	74 (63)	93 (80)	210 (180)
Pipe Size	1/2", 3/4"	3/4"	1"	1-1/4"	1-1/2"	2"	2-1/2"	3"	4"


= "E" dimension is check valve body outside edge to outside edge. Flange groove depth: nominal 0.12" each of two; gasket thickness: nominal 0.06" each of two.

PARTS LIST

HCK4-2 (2-BOLT)

ITEM	DESCRIPTION	QTY
Parts List (not for resale)		
<i>Above kits consist of:</i>		
1	Seat Disc	1
2	Closing Spring	1
3	Seat Cartridge	1
4	Seat Cartridge O-Ring	1
5	Flange Gasket	2
6	Body, HCK4-2	1
7	Bolt (7/16" - 14x3.25")	2
8	Nut (7/16" - 14)	2
9	Flange (FPT, SW, WN, ODS)	2

HCK4-2 (2-BOLT)




Socket weld shown. FPT, WN, ODS: Available.

HCK4-3, -4, -5 (2-BOLT)

ITEM	DESCRIPTION	QTY
Parts List (not for resale)		
<i>Above kits consist of:</i>		
1	Seat Disc	1
2	Closing Spring	1
3	Seat Cartridge	1
4	Seat Cartridge O-Ring	1
5	Flange Gasket	2
6a	Body, HCK4-3	1
6b	Body, HCK4-4	1
6c	Body, HCK4-5	1
7	Bolt (5/8" - 11x4")	2
8	Nut (5/8" - 11)	2
9	Flange (FPT, SW, WN, ODS)	2

HCK4-3, -4, -5 (2-BOLT)




Socket weld shown. FPT, WN, ODS: Available.

HCK4-7, -8, -9, -0, -1 (4-BOLT)

ITEM	DESCRIPTION	QTY
Parts List (not for resale)		
1a	Seat Disc 1-1/2", 2"	1
1b	Seat Disc 2-1/2", 3"	1
1c	Seat Disc 4"	1
2a	Closing Spring 1-1/2", 2"	1
2b	Closing Spring 2-1/2", 3"	1
2c	Closing Spring 4"	1
3a	Seat Cartridge 1-1/2", 2"	1
3b	Seat Cartridge 2-1/2"	1
3c	Seat Cartridge 3"	1
3d	Seat Cartridge 4"	1
4a	Seat Cartridge O-Ring 1-1/2", 2"	1
4b	Seat Cartridge O-Ring 2-1/2", 3"	1
4c	Seat Cartridge O-Ring 4"	1
5a	Flange Gasket 1-1/2", 2"	2
5b	Flange Gasket 2-1/2"	2
5c	Flange Gasket 3"	2
5d	Flange Gasket 4"	2
6a	Body, HCK4-7	1
6b	Body, HCK4-8	1
6c	Body, HCK4-9	1
6d	Body, HCK4-0	1
6e	Body, HCK4-1	1
7a	Bolt, HCK4-7, -8 (5/8" - 11x6")	4
7b	Bolt, HCK4-9, -0 (3/4" - 10x7")	4
7c	Bolt, HCK4-1 (7/8" - 9x7.5")	4
8a	Nut, HCK4-7, -8 (5/8" - 11)	4
8b	Nut, HCK4-9, -0 (3/4" - 10)	4
8c	Nut, HCK4-1 (7/8" - 9)	4
9	Flange (FPT, SW, WN, ODS)	2

HCK4-7, -8, -9, -0, -1 (4-BOLT)



Socket weld shown. WN, ODS: Available.

OPERATION

HCK4 check valves are normally closed valves. As inlet pressure increases, it overcomes the closing spring force. As the seat disc is pushed back and away from the seat cartridge, flow through the valve occurs. The valve will remain open until the inlet pressure drops below the closing spring force or there is a flow reversal, at which time the seat disc will close against the seat cartridge, preventing reverse flow.

SIZING

Check valves are normally selected on the basis of line size. However, for gas flow applications at low load conditions, a minimum of 1 psid across the valve is essential. This will maintain valve at full open position. Valve Cv (Kv) is listed in the installation dimension table on page 2. Factory valve sizing assistance is available.

SERVICE AND MAINTENANCE

These valves are a reliable part of a refrigeration system. However, if valve does not appear to be operating satisfactorily, isolate it from the refrigeration system. Remove all refrigerant from associated piping and valves. Follow the guidelines in the caution section. Loosen each flange nut on the check valve. Break each flange gasket seal. Carefully loosen flange bolts one at a time, being cautious to avoid any refrigerant which still may be present. Remove check valve from flanges and inspect. Lapped seating surfaces should be smooth and free of pits or scratches.

To confirm valve operation, move seat disc with eraser end of pencil. Movement should be free from friction. If not, disassemble and visually inspect for dirt in valve or burrs on seat disc. Clean or replace parts as necessary. Valve discs and seats can be restored by lapping on a flat plate.

Reassemble valve and insert between flanges. Replace and tighten bolts and nuts evenly. Carefully check for leaks before returning to service.

CAUTION

Hansen check valves are only for refrigeration systems. These instructions and related safety precautions must be completely read and understood before selecting, using, or servicing these valves. Only knowledgeable, trained refrigeration mechanics should install, operate, or service these valves. Stated temperature and pressure limits should not be exceeded. Valves should not be removed unless system has been evacuated to zero pressure. See also Safety Precautions in current List Price Bulletin and Safety Precautions Sheet supplied with product. Escaping refrigerant might cause personal injury, particularly to the eyes and lungs.

WARRANTY

All Hansen products, except electronics, are guaranteed against defective materials or workmanship for one year F.O.B. factory. Electronics are guaranteed against defective materials or workmanship for 90 days F.O.B. factory. No consequential damages or field labor is included.

ORDERING INFORMATION

TYPE	PORT SIZE INCHES (mm)	FLANGE CONNECTION STYLE & SIZES		
		FPT, SW, WN		ODS
		STD	ALSO	STD
HCK4-2	5/8" (16)	1/2"	3/8", 3/4"	5/8"
HCK4-3	3/4" (20)	3/4"	1", 1-1/4"	7/8"
HCK4-4	1" (25)	1"	3/4", 1-1/4"	1-1/8"
HCK4-5	1-1/4" (32)	1-1/4"	3/4", 1"	1-3/8"
HCK4-7	1-1/2" (40)	1-1/2"	2"	1-5/8"
HCK4-8	2" (50)	2"	1-1/2"	2-1/8"
HCK4-9	2-1/2" (65)	2-1/2"	3"	2-5/8"
HCK4-0	3" (80)	3"	-	3-1/8"
HCK4-1	4" (100)	4"	-	4-1/8"


HCK4-2 close-couples to HS6 & HS8 Solenoid Valves.
HCK4-3, -4, & -5 close-couples to HS7 Solenoid Valve.
FPT available only 3/8" to 1 1/4".

TO ORDER: Specify valve type, connection style and size, and close-coupling information if needed.

TYPICAL SPECIFICATIONS

"Refrigeration in-line check valves shall have steel or ductile iron bodies, stainless steel seat discs, stainless steel closing springs, and be suitable for a safe working pressure of 400 psig, as manufactured by Hansen Technologies Corporation type HCK4 or approved equal."

TYPICAL CLOSE-COUPLING TO SOLENOID VALVE



Hansen Technologies Corporation
681 Commerce Street

Burr Ridge, Illinois 60527 USA

Tel: 630.325.1565 Fax: 630.325.1572 Toll: 866.4HANSEN

Email: info@hantech.com Web: www.hantech.com

USA · Asia · Europe · India · Latin America · Middle East

© 2006 Hansen Technologies Corporation